

# **Certificate of Product Approval**

Certificate Number: 717e-(cl-1) Issue: 01



# **Syncoln Ltd**

3<sup>rd</sup> Floor London United Kingdom

### **Products**

**Visual Warning Devices** 1000-300

1000-301

### **Standards**

EN 54-23:2010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

P Halligan Verifier

26 July 2016 Date of Issue

26 July 2016

Date of First Issue









Appendix to Certificate No: 717e-(cl-1) Issue: 01
Syncoln Ltd

Certified Product	Description	LPCB Ref.No.
1000-300	Conventional Type A Wall Mounted White Light LED Visual Alarm Device (red head / red bases) – (PSO-0001 base)  Note:  1. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following:  - Category W-3.1-11.3  - Flash rates 0.5Hz and 1Hz  - Synchronization	717e/03
1000-301	Conventional Type B Wall Mounted White Light LED Visual Alarm Device (red head / red bases) – (PSO-0017)  Note:  1. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following:  - Category W-3.1-11.3  - Flash rates 0.5Hz and 1Hz  - Synchronization	717e/03

#### Bases

PSO-0001 Red shallow base PSO-0017 Red deep base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LDCP

P Halligan Verifier 26 July 2016

26 July 2016

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



