

Certificate of Product Approval

Certificate Number: 010p-(cl-6)

Issue: 01

Syncoln Ltd

3rd Floor
 14 Hanover Street
 Mayfair
 London
 W1S 1YH
 United Kingdom

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Heat Detectors

2000-300
 2000-301
 2000-302
 5000-300

Standards

EN 54-5: 2000 + A1: 2002

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan
 Verifier

07 November 2016
 Date of Issue

07 November 2016
 Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 010p-(cl-6) Syncoln Ltd

Issue: 01

Certified Product	Description	LPCB Ref.No.
5000-300	Syncoln Analogue Addressable Heat Detector (5000-100 base) Notes: 1. Meets the requirements of EN54: Part 5 at the following modes: - Class A1R in mode 1 and in conventional mode - Class A2 in mode 2 and in conventional mode - Class A2S in mode 3 and in conventional mode - Class CR in mode 4 and in conventional mode - Class CS in mode 5 and in conventional mode Certified with Apollo Discovery, XP95, and S90 digital communications protocols configured for the Discovery Heat Detector in accordance with manufacturer's instructions.	010p/03
2000-300	Syncoln Series 27 A1R Heat Detector with Flashing LED (2000-100 base) Note: Meets the requirements of EN54: Part 5 at Class A1R	010p/05
2000-301	Syncoln Series 27 BR Heat Detector with Flashing LED (2000-100 base) Note: 1. Meets the requirements of EN54: Part 5 at Class BR	010p/08
2000-302	Syncoln Series 27 CS Heat Detector with Flashing LED (2000-100 base) Note: 1. Meets the requirements of EN54: Part 5 at Class CS	010p/14

Bases

2000-100 Syncoln Series 27 Standard Base
5000-100 Syncoln Mounting Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan
Verifier

07 November 2016
Date of Issue

07 November 2016
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com


