# **Soteria Dimension**

## **Optical Detector**



Product overview	
Product	Soteria Dimension Optical Detector
Part No.	FL5100-600APO (Detector)
Digital Communication	XP95®, Discovery® and CoreProtocol® compatible

Compliance		
CE	LPCB	VdS
BOSEC	FG	SBSC PRODUKT

## **Product information**

The innovative design of the Soteria Dimension Optical Detector differs from standard fire detectors, having no chamber and being flush mounted. A new optical sensing technology is used to detect smoke particles outside the detector housing. A combination of Infra-Red (IR) LEDs and photo-diodes identify smoke particles, detected just below the detector housing and initiates an alarm.

- Low profile design
- Utilises digital CoreProtocol communications
- · Compatible with Discovery and XP95 systems\*
- · Integrated switchable isolator as standard
- · 8-way DIL switch addressing
- · Drift compensation
- FasTest® for quicker testing
- · Tricoloured LED status indicator
- Polycarbonate moulding for colour stability and strength
- Comprehensively tested to exceed EN 54-7 and EN 54-17 standards
- · Locking mechanism (grub screw)

\*Note: Not all features may be available when Soteria devices are connected to an XP95 or Discovery fire control panel

#### Technical data

All data is supplied subject to change without notice. Specifications are typical at 24V, +25°C and 50% RH unless otherwise stated.

Detection principle Photo-electric light scattering Sensor configuration Chamberless detector with two photo-diodes. Micro-controller provides sensor timings, digital signal processing and alarm decision.

Once per second Sampling frequency Terminal functions \_I 1 in

Loop in negative (Note: L1 and L2 are polarity -I 1 out Loop out negative sensitive +12 Loop in and out positive

+R Remote indicator positive connection (internal connection to positive)

-RRemote indicator negative connection (4.7 mA maximum)

Supply voltage (Vmin-Vmax) 17 - 35 V dc

Digital communication XP95, Discovery Protocol and protocol CoreProtocol compatible 5 - 13 V peak to peak

Quiescent current 1 mA Power-up surge current 1 mA15 s Maximum power-up time Alarm current, LED 4.5 mA illuminated

Maximum loop current through isolator

Clean-air analogue value 23 + 4/-0Alarm level analogue value 55

Status indicator Alarm Red Fault Flashing Yellow

> Isolated Yellow Poll Flashing Green -20 °C to +55 °C

Humidity 0% to 95% RH (no condensation or icina)

Effect of atmospheric pressure None Effect of wind speed None FN 54-7 Vibration, impact & shock

IP Rating IP55 - rating not EN 54 approved Standards & approvals EN 54-7, EN 54-17, CPR, LPCB, VdS,

BOSEC, FG and SBSC Dimensions:

Detector with backbox

Operating temperature

140 mm diameter x 38.2 mm depth 140 mm diameter x 71 mm depth

Weight: Detector 148 a with backbox 273 g

Materials: Housing White flame-retardant

polycarbonate

Terminals Nickel plated stainless steel

36 Brookside Road, Havant Hampshire, P09 1JR, UK.

Tel: +44 (0)23 9249 2412 Fax: +44 (0)23 9249 2754

Email: sales@apollo-fire.com Web: www.apollo-fire.co.uk

All information in this document is given in good faith but Apollo Fire Detectors Ltd cannot be held responsible for any omissions or errors. The company reserves the right to change the specifications of products at any time and without prior notice.











## **Electrical operation**

The Soteria Dimension Optical Detector is designed to be connected to a two-wire loop circuit carrying both data and a  $17\,V-35\,V$  dc supply. A short-circuit isolator is also integrated into the detector head.

#### Operation

The Soteria Dimension Optical Detector contains two daylight filtered photo-diodes and three IR emitters in different positions and angles. Different combinations of these are used to act as smoke sensors and proximity sensors to measure the smoke level at the detector and to detect any physical obstruction or interference of the detector.

As this detector is chamberless, an IR LED emits light outside the detector. The light is scattered by smoke back towards the detector and registered by a photo-diode.

A pair of microprocessors control these sensors, setting the sensor timings and using a digital phase-sensitive detection algorithm to reduce noise and the effect of background light. They then provide digital filtering for transient rejection, compensation for drift and temperature and ultimately make an alarm decision.

The mode of operation may be selected at the fire control panel (see Table 1).

Table 1: Soteria Dimension Optical Detector operating modes

operating indues				
Mode	Response Value		Minimum Time to Alarm	Minimum Time to Proximity Fault
	%/m*	dB/m**	Seconds	Seconds
1	4.8	0.27	15	10
2	4.8	0.27	30	10
3	4.8	0.27	15	20
4	4.8	0.27	30	20
5	4.8	0.27	30	30

<sup>\*</sup> Tested in grey smoke

Anti-abrasion coated windows make the detector more resistant to physical damage.

With the detection region external to the detector case, the Soteria Dimension Optical Detector is designed to be flush mounted, with a very low profile.

The device has a polycarbonate front plate, which can be locked into place with a grub screw locking mechanism.

Three LEDs provide status indication as detailed in the Technical Data table (see page 1).

The Soteria Dimension Optical Detector has been designed and manufactured in the UK to exacting standards using advanced simulation and development processes.

## **Application**

Fire detectors should always be installed in accordance with all local and national laws and codes of practice.

Optical smoke detectors are recommended for general use, particularly where there is a risk of slow burning fires.

#### Communication

The Soteria Dimension Optical Detector uses the Apollo digital CoreProtocol to allow more advanced control and configuration, whilst maintaining backwards compatibility with previous generations of Apollo products – Discovery and XP95. For future feature availability, please check with your panel partner.

It should be noted that not all features of the Soteria Dimension Optical Detector will be available when used with Discovery or XP95 fire control panels. If the Soteria Dimension Optical Detectors are used with XP95 fire control panels incorporating drift compensation algorithms, these must be disabled when communicating with the Soteria Dimension Optical Detectors.

### **Device Addressing**

The device address may be set using an 8-bit DIL switch on the detector head.

### **Backward Compatibility**

The Soteria Dimension Optical Detectors have been designed to operate on XP95 and Discovery loops.

## EMC Directive 2014/30/EU

The Soteria Dimension Optical Detector complies with the essential requirements of the EMC Directive 2014/30/EU, provided that it is used as described in this data sheet.

A copy of the Declaration of Conformity is available from Apollo on request.

Conformity of the Soteria Dimension Optical Detector with the EMC Directive, does not confer compliance with the directive on any apparatus or systems connected to it.

## Construction Products Regulation 305/2011/EU

The Soteria Dimension Optical Detector complies with the essential requirements of the Construction Products Regulation 305/2011/EU.

A copy of the Declaration of Performance is available from Apollo on request.

<sup>\*\*</sup> Tested in oil mist to EN 54-7 standard

## Maintenance and Service

The Soteria Dimension Optical Detectors have been designed with a comprehensive set of features to support maintenance and service, from self test capabilities to drift compensation warnings on dirty detectors.

The new FasTest mode facility on the Soteria Dimension Optical Detector, which can only be enabled on compatible fire control panels, facilitates quicker testing of detectors with appropriate test equipment. The FasTest disables a portion of the signal processing algorithm and also the builtin proximity sensor to allow for a faster detector response, whilst ensuring that the detectors absolute sensitivity remains identical to that of Mode 3 (refer to Table 1). This helps to reduce commissioning time.

The detector may also be tested using a smoke pen, with the method described in the installation guide for this product -39215-173.

Maintenance has to be performed in accordance with all applicable standards. Clean the detector externally using a soft damp cloth. If the cleaning process takes more than 10 seconds, the detector may register a fault. For full cleaning and recalibration detectors should be returned to Apollo Fire Detectors.




Figure 1: Soteria Dimension Optical Detector

Note:

1) Use a 114 mm (4.5") cutter

2) Ceiling thickness



This page has intentionally been left blank

